

POWER SHARING CONDITIONING CONTROL IN SINGLE-PHASE
PARALLEL DISTRIBUTED GENERATIONS WITH SIMPLE IMPROVEMENT
OF DROOP CONTROL

RONALD ANAK JACKSON

A thesis submitted in
fulfillment of the requirement for the award of the
Degree of Master of Electrical Engineering

Faculty of Electrical and Electronic Engineering
Universiti Tun Hussein Onn Malaysia

JULY 2019

To my beloved family: Mom, Dad, Brother, Sister and Fiancé



ACKNOWLEDGEMENT

I would like to take the opportunity to thank and express my deepest gratitude to my supervisor, Associate Professor Dr. Shamsul Aizam Bin Zulkifli. His guidance, ingenious teachings and most importantly patience have made it possible for me to complete this project on time. His sincerest help and generosity towards sharing knowledge and giving support has given momentum in driving the project to be successful; besides, his ambitious idea with numerous excellent suggestions made this project possible to be complete.

To my beloved family members especially my parents, Mr. Jackson Lian and Mrs. Nen Bajih, who are always there to encourage me and give moral support, thank you for the never-ending support and love I receive from both of you. Also to Anthony, Lily and Narry who had given a lot of help and support to complete my studies.

My warmest gratitude to all Advanced Control Power Converter (ACPC) group members for their knowledge sharing and motivational support, and also to my beloved friends who were always be there to offer ultimate support and time. With their help, I am able to finish in the stipulated time.

Thank you so much for the teamwork, lessons and memories. May God Almighty repay everyone's kindness.

ABSTRACT

Droop control is the critical solution for sharing the power demand between Distributed Generations (DGs) in islanding microgrid when there is no support from the electricity distribution grid. The droop control is applied as the local control scheme to achieve power sharing among parallel inverters with DG sources. As it has been well established, this control strategy is combined frequency and voltage droop method. In droop strategy, the voltage and frequency are drooped to a new rated value to ensure power load sharing. Therefore this project to have an improvement of the droop under self-frequency restoration method is adopted in order to obtain accurate power sharing and fast frequency tracking capability with better load sharing between parallel DGs are been conducted in this project. It is where the improved droop control is used to have faster restoration for the voltage and frequency to nominal values within a limited time and to ensure the proper power sharing between the DGs considering based on the rating of energy source. The performance of the proposed controller is implemented in MATLAB/Simulink software and compared by two simulation tests under two exigent load circumstances as well also as through the connection of DGs to the point of common coupling (PCC). It is to verify the proposed control model has capability to response accurately during the power transient and power sharing conditions at both DGs. In proportion, the implementation of frequency restoration loop to the improved droop control has create a condition where it knows as an autonomous smart grid system whereby the restoration of the frequency and voltage can be done automatically. As a result, the improved controller can achieve better steady-state performance and fast restoration tracking speed within 3.5ms with 2.8ms rise time as compared to 8.5ms rise time for the conventional droop control. It also reduces the overshoot during the load transient to 4% and increases the tracking efficiency by 90% as compared to the 40% overshoot and 85% efficiency for the conventional control. Hence, the autonomous smart microgrid system is successfully

presented under this proposed controller along with accurate power sharing performance between DGs and fast frequency restoration.



ABSTRAK

Kawalan susut adalah merupakan penyelesaian utama untuk perkongsian kuasa di antara penjana pengagihan (PP) di dalam grid tersendiri yang berskala kecil di mana ia tidak memerlukan sokongan daripada grid utama pengagih elektrik. Kawalan susut digunakan sebagai skim kawalan tempatan untuk menyediakan perkongsian kuasa di antara penyongsang selari berlandaskan sumber PP. Seperti yang telah ditubuhkan, kawalan ini beroperasi dengan menggabungkan amplitud dan frekuensi voltan. Dalam kawalan susut, amplitud dan frekuensi voltan akan susut ke nilai baru agar memastikan perkongsian beban kuasa berlaku. Oleh itu, penambahbaikan kawalan susut dibawah kaedah pemulihan frekuensi sendiri telah diadaptasi untuk perkongsian kuasa yang lebih tepat dan keupayaan mengesan frekuensi agar memastikan pengkongsian beban yang lebih baik di antara PP selari telah dilaksanakan dalam projek ini. Pada peringkat ini kawalan susut yang lebih baik digunakan untuk pemulihan yang lebih pantas untuk voltan dan frekuensi kepada nilai sebenar dalam masa yang terhad untuk memastikan perkongsian kuasa yang tepat berdasarkan sumber tenaga. Prestasi kawalan susut ini dilaksana menggunakan perisian platform MATLAB/Simulink dan diuji melalui dua kajian simulasi iaitu di bawah perubahan dua beban utama dan melalui sambungan PP ke titik gandingan bersama (TGB). Ini bertujuan untuk mengesahkan model kawalan yang dicadangkan mempunyai keupayaan untuk bertindak secara tepat semasa berlaku perubahan kuasa di antara PP. Secara amnya, sistem pintar terjadi apabila pemulihan voltan dan frekuensi dilaksanakan secara automatik dengan adanya laluan pemulihan frekuensi dalam penambahbaikan kawalan susut. Natijahnya, kawalan yang lebih baik dapat mencapai prestasi yang terbaik dengan kelajuan pengesanan pemulihan dalam masa 3.5ms dengan 2.8ms masa kenaikan apabila dibandingkan 8.5ms untuk kawalan konvensional. Ia juga mengurangkan jumlah lebihan sebanyak 4% dan meningkatkan kecekapan pengesanan sebanyak 90% berbanding 40% jumlah lebihan dan 85% kecekapan untuk kawalan konvensional. Justeru, sistem automatik mikrogrid pintar

berjaya dibentangkan di bawah prestasi kawalan dengan memaparkan perkongsian kuasa yang tepat dengan pemulihan frekuensi yang cepat.



CONTENTS

TITLE	i
DECLARATION	ii
DEDICATION	iii
ACKNOWLEDGEMENT	iv
ABSTRACT	v
ABSTRAK	vii
CONTENTS	ix
LIST OF TABLES	xiii
LIST OF FIGURES	xiv
LIST OF SYMBOLS AND ABBREVIATIONS	xvii
LIST OF APPENDICES	xix
CHAPTER 1 INTRODUCTION	1
1.1 Project background	1
1.2 Problem statement	4
1.3 Research objective	5
1.4 The scope of the study	5
1.5 Thesis organisation	6
CHAPTER 2 LITERATURE REVIEW	7
2.1 Introduction	7
2.2 Distributed generation background	7
2.2.1 Type of distributed generation	8
2.2.2 Distributed generation's advantages	8
2.3 Controller hierarchical	11
2.3.1 Centralised control	11

2.3.2	Decentralised controller	12
2.4	Droop control concept	13
2.4.1	Conventional droop	14
2.4.2	Modified droop control	17
2.4.3	Adaptive droop control	18
2.4.4	Robust droop control	20
2.5	Droop control enhancement methods	22
2.5.1	Power calculation	22
2.5.2	Voltage and frequency regulation	22
2.6	Conventional frequency restoration limitations	23
2.7	Summary	24
CHAPTER 3	METHODOLOGY	25
3.1	Introduction	25
3.2	Power theorem development	26
3.2.1	Instantaneous power	26
3.2.2	Stationary reference frame signals stage	27
3.2.3	Rotating reference frame signals	28
3.3	Stage of development of improved droop control	30
3.3.1	Power and frequency control for autonomous mode	30
3.3.2	Validation of droop coefficient for gains determination	32
3.3.3	Inverter frequency restoration tracking	35
3.4	Determination of filter inductance and the capacitance value	38
3.4.1	Inductor value	38
3.4.2	Capacitor value	38

3.5	Simulation cases study	39
3.6	Simulation system parameters	40
3.7	Summary	42
CHAPTER 4	RESULTS AND DISCUSSION	43
4.1	Introduction	43
4.2	PCC voltage and current during DGs connection	44
4.2.1	Start-up transient response	44
4.2.2	Controller transient response according to the reference value	45
4.2.3	PCC voltage and current response when $PCC V_{ref} = 120V_{rms}$	46
4.2.4	PCC voltage and current response when $PCC V_{ref} = 230V_{rms}$	47
4.3	Case 1: Load change conditions	48
4.3.1	Load power sharing for a $120V_{rms}$ system	48
4.3.2	Power sharing in conventional method	50
4.3.3	Load power sharing for a $230V_{rms}$ system	51
4.3.4	Inverter frequency restoration performance	53
4.3.5	Transient response time comparison	54
4.3.6	Load current harmonic distortion analysis	55
4.4	Case 2: Capability to handle connection/disconnection of DG2	56
4.4.1	Test for $120V_{rms}$ microgrid system	56
4.4.2	Test for $230V_{rms}$ microgrid system	58
4.4.3	Power transfer transient time response	60
4.5	Comparison between conventional and improved droop controllers	61

4.5.1	Frequency during load change conditions	61
4.5.2	Improved droop control tracking transient response	62
4.6	Summary	64
CHAPTER 5	CONCLUSION AND FUTURE WORK	65
5.1	Conclusion	65
5.2	List of contribution	66
5.3	Recommendation	66
	REFERENCES	67
	APPENDIX A	77
	APPENDIX B	78
	APPENDIX C	79
	APPENDIX D	80
	LIST OF PUBLICATIONS	81
	VITA	82



LIST OF TABLES

2.1	The distributed generation technologies	10
2.2	Comparison of two types of control architectures	13
2.3	Typical impedance values	16
2.4	Comparison of droop control strategies	18
2.5	Adaptive droop control strategies	20
2.6	Robust droop control strategies	21
2.7	Summary of conventional frequency restoration under studies	23
3.1	Results summary for frequency coefficient adjustment	34
3.2	System parameters and components	40
4.1	Comparison summary for transient time response	44
4.2	Loads and power rating for load conditions	48
4.3	Transient time response comparison	54
4.4	Inverter load and power rating with connection time	56
4.5	Performance and robustness of the proposed controller	63

LIST OF FIGURES

1.1	Conventional parallel DGs system design coordinated with droop control method	3
2.1	Connection of DG to existing transmission and distribution networks	8
2.2	Master-slave control system architecture	11
2.3	Decentralised control system architecture	12
2.4	Inverter connected to PCC bus [42]: (a) equivalent per-phase model and (b) phasor diagram	14
2.5	Droop control characteristic plots: (a) general block diagram, (b) P-f droop and (c) Q-E droop	17
2.6	Adaptive controller scheme [68]	19
3.1	Typical block diagram of droop controller components with proposed method	25
3.2	Block diagram of power theorem in Simulink platform	26
3.3	Stationary orthogonal component generation technique	28
3.4	Voltage and current stationary frame waveforms	28
3.5	Block diagram of a rotating reference frame	29
3.6	Voltage and current in the rotating frame	30
3.7	Block diagram of the proposed improved droop control method	31
3.8	Proportional Integral control block diagram for single DG	32
3.9	Power controller of two DG systems for droop coefficient investigation	33
3.10	Bode plot for magnitude droop coefficients effects	34
3.11	Step response for frequency droop coefficients effect at: (a) m_1 is 5%, (b) m_2 is 7% and (c) m_3 is 9%	35
3.12	Block diagram for inverter frequency tracking	36
3.13	Block diagram of frequency tracking	36

3.14	System frequency tracking: (a) steady-state condition and (b) under load condition	37
3.15	Block diagram of simulation setup for two cases: (a) load change assessment and (b) DG connect/disconnect to/from microgrid	39
3.16	Schematic diagram of the simulation setup under proposed droop control strategy	41
4.1	Step response according to reference set-point for frequency 50Hz	44
4.2	Voltage amplitude tracked regarding reference value: (a) for 50 Hz and (b) reference voltage of $230V_{rms}$	45
4.3	DGs output at PCC level: (a) output current for 8A and (b) output voltage of $170V_p$	46
4.4	Inverter voltage output parameters at PCC level: (a) for $120V_{rms}$ and (b) for $230V_{rms}$	47
4.5	Total average load power sharing: (a) active power and (b) reactive power	48
4.6	Total load current consumed by: (a) load for 500W, (b) for load 1500W, (c) for load 3000W and (d) total microgrid current consumptions	49
4.7	Power sharing under conventional method: (a) active power and (b) reactive power	50
4.8	Total average load power sharing for 230V source: (a) total active power during load change and (b) total reactive power consumed by the load	51
4.9	Average current for load: (a) current consumed by load 500W, (b) current consumed by load 1500W, (c) current consumed by load 3000W and (d) total average current consumed by the load	52
4.10	Frequency of DG1 and DG2: (a) no-load condition, (b) without frequency restoration and (c) with frequency restoration	53
4.11	Transient response for power sharing time evolution for the $120V_{rms}$ system	54

4.12	THD analysis for microgrid load current at: (a) system of $120V_{\text{rms}}$, 50 Hz and (b) system of $230V_{\text{rms}}$, 50 Hz	55
4.13	Average load power sharing when DG2 is connected/disconnected to/from microgrid: (a) measured active power and (b) reactive power	56
4.14	Microgrid total output current	57
4.15	Power sharing performance at PCC: (a) total active power for DGs and (b) total reactive power for DGs	58
4.16	Total microgrid current output for the 230V system	59
4.17	Transient time response for power sharing when DG2 is connected	60
4.18	Frequency tracking capability in terms of: (a) operating frequency 50 Hz and (b) Bode plot characteristic (rad/s)	62
4.19	PI tracking transient response for improved droop control against conventional droop control	63



LIST OF SYMBOLS AND ABBREVIATIONS

DG	-	Distributed generation
W	-	Watt
VAR	-	Voltage active reactive
kW	-	kilowatt
MW	-	Megawatt
AC	-	Alternating current
DC	-	Direct current
Δ	-	Delta
A	-	Current
V	-	Voltage
V_{dc}	-	Input voltage
V_o	-	Nominal output voltage
V_{mg}	-	Microgrid output voltage
E^*	-	Set-point voltage
I	-	Inverter output current
I_o	-	Nominal output current
Hz	-	Frequency
f_n	-	Nominal frequency
f_s	-	Switching frequency
f^*	-	Set-point frequency
f_g	-	Gird frequency
ω	-	Omega ($2*\pi*f$)
θ	-	Voltage phase ($^\circ$)
P	-	Active power
P_L	-	Load active power
P_i	-	Inverter active power

ΔP	-	Active power deviation
Q	-	Reactive power
Q_L	-	Load reactive power
Q_i	-	Inverter reactive power
ΔQ	-	Reactive power deviation
m	-	Frequency droop coefficient (rad/W.s)
n	-	Voltage droop coefficient (V/VAR)
K_p	-	Proportional gain
K_i	-	Integral gain
s	-	second



LIST OF APPENDICES

APPENDIX	TITLE	PAGE
A	Flowchart of the overall project research	77
B	Simulation setup for power load sharing under improved droop control method	78
C	Simulation setup for DG2 connect/disconnect to/from autonomous microgrid	79
D	Single-phase electric motor rating	80



PT TA UTHM
PERPUSTAKAAN TUNKU TUN AMINAH

CHAPTER 1

INTRODUCTION

1.1 Project background

In recent years, the renewable energy sector is becoming more interesting for being research due to its penetration into the integrated microgrid system. It is also due to the decarbonisation policy [1] that has been set by the United Nation to reduce global warming, which has become a turning point for renewable energy in generating more clean energy in the future. The interconnection of small generation systems such as solar photovoltaic panels, fuel cells and energy storage devices to low-voltage distribution network has also led to congestion on the dynamic power system. These power sources give rise to the capability of decentralised generation, known as distributed generations (DGs) [2]. Nowadays, the advancements in designs and component materials related to DG have increased the range of applications and opportunities for advanced DG configuration with higher controller response. These advanced technologies together with the restructuring of wholesale and retail markets for electric power have also opened the possibility for an energy system that gives more freedom for customers to manage their power in order to meet their own needs [2], [3].

A microgrid is defined as a system that has at least one DG as well as energy storage devices and associated loads connected at the common bus bar network. A microgrid can operate in two different modes of operation: interconnected mode, where it is connected to the main upstream grid from which power is being supplied or to which it injects power, and in an autonomous way of operation, which is disconnected from the distribution network. In grid-connected mode, each DG in the microgrid does not have to regulate the voltage of the system as this is done by the stiffer main grid [4]–[6]. Meanwhile, in autonomous mode, DGs are responsible and

required for regulating the voltage and frequency of the microgrid and for supplying power to meet the local load's requirement with acceptable power quality without jeopardising the entire network. The application of this particular electrical power system is appropriate for supplying power in rural areas, where power demand is relatively low and where it is not cost-effective to install transmission lines and provide power from the main grid [7], [8]. This concept is becoming more important due to the increase of renewable energy power penetration in order to reduce the reliance on conventional power generations.

The fundamental control objective of DGs in a microgrid is to achieve accurate power sharing while regulating the microgrid's voltage amplitude and frequency in order to become autonomous. A centralised control strategy based on communication architecture has been proposed in [9], [10]. However, it is impractical and costly to be used with communication links in remote areas due to the long distances between inverters. Therefore, decentralised controllers are investigated to eliminate communication links [11], [12], and they have become an option nowadays. This is because the power sharing for microgrid generators is achieved using droop controller strategy, which is based on synchronous generator operation to balance frequency and voltage when the real and reactive power demand changes [13]. Droop control can be enhanced by featuring the transient response performance by means that depends on active power (P) and reactive power (Q) [14]. To decrease the P and Q dependency, droop control with virtual output impedance [15] and a secondary virtual frequency-voltage frame [16] are also discussed. Although these control methods can improve the overall power sharing factors, they have complexities in adjusting the control parameters.

Therefore, this research takes the initiative to propose an improved droop control technique for droop-based parallel-connected inverters associated with the local load by using local adjustments to adjust the output of the inverter voltage amplitude and frequency to ensure accurate power sharing to be delivered to the local loads with fast frequency restoration tracking. It should provide a robust performance against all conditions mentioned. In the meantime, the proposed controller will be tested at two DG inverters connected to three loads at a typical bus bar during the transient mode between the loads. Thereby, the droop control method will allow the DGs to be able to share the total power load demand by adjusting inverter output voltage frequency and amplitude as a function of the desired P and Q .




Figure 1.1: Conventional parallel DGs system design coordinated with droop control method

The conventional system associated with a legitimate control strategy is shown in Figure 1.1. As shown, the system consists of external P/Q power control coordinated with the droop control strategy. The proposed system will be put together in a parallel configuration in bus-connected to simulate an autonomous microgrid. An improved droop will generate a new sine wave reference signal ($V_{droop_generator}$) for gate pulse switching (PWM). The controller performance is tested thoroughly with several cases to verify the controller response.

1.2 Problem statement

In the case where two DGs are connected at the same bus bar, the power sharing situation should be properly investigated and studied. This is because when each inverter has a different power, the output of the inverter voltage amplitude and frequency is at an unstable state. However, there is an inherent trade-off between load sharing accuracy and voltage amplitude and frequency regulation. In the conventional droop control design process, the power sharing can happen when an accurate droop coefficient is selected. In choosing this droop gain coefficient, where it is based on the boundary limit of the voltage and frequency, an inherent trade-off occurs [17]. This is because the proportion to droop characteristic upon coordination between active-frequency (P - f) and reactive power-voltage (Q - V) needs to be established to maintain system stability. Good power sharing can also be conceived by adjusting the output voltage amplitude and frequency of the inverter. To have shared power among the inverters, the voltage amplitude and frequency droop coefficient should be at a range of accepted value. Without a legitimate control strategy, the adjustment of these values might disrupt the power sharing performance and interrupt voltage output as well. However, there are few resources in terms of investigations on droop coefficient of more than one number coefficient [18]. Additionally, in the existing droop controller, the frequency of an autonomous microgrid continuously changes according to the variation of load demand and the restoration process is executed in a more prolonged period [19]. This is because of the slow transient response. As is well known, if the frequency deviation suddenly rises due to load changes that will cause the system frequency to deviate more than 50 Hz, it will create a power outage to the system.

Therefore, it is vital to have an accurate droop controller combined with high-speed frequency tracking to generate a precise power sharing while maintaining the voltage output. Consequently, it will make the voltage amplitude and frequency of the reference voltage signal to follow the droop as the load current increases, and these droops are used to allow independent inverters to share the load in proportion to their capacities. It also allows both active and reactive powers to be controlled indirectly and in autonomous mode in order to achieve fast voltage-frequency restoration tracking with better steady-state performance.

1.3 Research objective

The objectives of this research are as follows:

1. To develop an improved power conditioning control based on droop control strategy for accurate power sharing for both inverters at the point of common connection.
2. To design a minimum time for frequency tracking response for an autonomous smart grid.
3. To compare the improved droop control strategy with the conventional method in local microgrid power sharing conditions.

1.4 The scope of the study

The scopes of the project are broken into several categories involving the simulation and performance testing:

1. The droop control strategy for the single-phase inverter microgrid network is designed in MATLAB/Simulink platform software.
2. The design concept is based on the stand-alone inverter with voltage and current from the inverter output side, which are used as control feedback.
3. The inverter used is based on universal bridge inverter block obtain from Simulink library.
4. The system is tested with different reference voltages of $120V_{rms}$ and $230V_{rms}$, with 50Hz frequency.
5. The DG input is applied with a constant input value where DG1 and DG2 have values of $120V_{rms}$ and $230V_{rms}$, respectively. All the DC sources are assumed to have a stable regulated output.
6. The controller design is being limited based on the coordination between voltage/frequency (V/f) droop characteristics.
7. The microgrid design is based on a small-scale microgrid associated with the local load in purely inductive line.
8. The highlighted parameters being observed on the controller response towards DG operation are response time, tracking speed and steady-state settling period.

1.5 Thesis organisation

This thesis comprises five chapters. A detailed explanation is discussed respectively for every section as follow:

Chapter 1: Project introduction is presented in this section, followed by the research problem and objectives to solve the faced problem. The scopes of the research project also are constructed at the end of the chapter.

Chapter 2: A comprehensive literature review regarding power conditioning control extracted based on droop control strategies is presented in detail from previous research. In this section, the selection of a suitable power controller approach for inverter-based microgrid is considered. The summarisation and the tabulated data of selected and relevant control strategies are compared in terms of advantages, disadvantages, reliability and robustness of controller performance.

Chapter 3: This chapter presents the methodology of the whole study to achieve the objectives. The flow of the proposed power controller based on voltage and frequency droop control strategies is also discussed further in this chapter. All the relevant modelling parameters are also illustrated.

Chapter 4: The results and discussion are provided in this chapter. The simulations of the proposed power controller are tested to ensure its validity. To demonstrate the accuracy, the power sharing performance of the load has been set accordingly. The comparison between the existing power controller and the proposed approach is also discussed deeper in this chapter.

Chapter 5: This conclusion of the research are summarised in the final chapter. The recommendation for future research also has been listed in this section.

REFERENCES

1. B. S. Abdulraheem and C. K. Gan, "Power system frequency stability and control: Survey," *International Journal of Applied Engineering Research*, vol. 11, no. 8, pp. 5688–5695, 2016.
2. N. Jenkins, J. B. Ekanayake, and G. Strbac, *Distributed generation*, 1st ed. The Institution of Engineering and Technology, 2010.
3. A. Varghese, L. R. Chandran, and A. Rajendran, "Power flow control of solar PV based islanded low voltage DC microgrid with battery management system," *IEEE 1st International Conference on Power Electronics, Intelligent Control and Energy Systems (ICPEICES)*, pp. 1–6, 2016.
4. N. Salim, "Load Frequency Control of Two-Area Network using Renewable Energy Resources and Battery Energy Storage System," *Journal of Electrical Systems*, vol. 2, pp. 348–365, 2017.
5. T. Hornik and Q. C. Zhong, "A current-control strategy for voltage-source inverters in microgrids based on H_∞ and repetitive control," *IEEE Transactions on Power Electronics*, vol. 26, no. 3, pp. 943–952, 2011.
6. M. Manojkumar, K. Porkumaran, and C. Kathirvel, "Power Electronics Interface for Hybrid Renewable Energy System – A Survey," *International Conference on Green Computing Communication and Electrical Engineering (ICGCCEE)*, pp. 1–9, 2014.
7. Z. Shuai *et al.*, "Microgrid stability: Classification and a review," *Renewable and Sustainable Energy Reviews*, vol. 58, pp. 167–179, 2016.
8. Q. Zhang, "Control of PV Battery Hybrid System Using Cascaded H Bridge Converter," *IEEE 3rd International Future Energy Electronics Conference and ECCE Asia*, pp. 2008–2012, 2017.
9. R. Palma-Behnke *et al.*, "A Microgrid Energy Management System Based on the Rolling Horizon Strategy," *IEEE Transactions on Smart Grid*, vol. 4, no. 2, pp. 996–1006, 2013.

10. C. Chandrasekhran, L. R. Chandran, and A. Rajendran, "Power Flow Control in Low Voltage AC Microgrid Using Photovoltaic System and Battery Energy Storage," *IEEE 1st International Conference on Power Electronics, Intelligent Control and Energy Systems (ICPEICES)*, pp. 1–6, 2016.
11. B. A. Vaccaro, M. Popov, D. Villacci, and V. Terzija, "An Integrated Framework for Smart Microgrids Modeling, Monitoring, Control, Communication, and Verification," *Proceedings of the IEEE*, vol. 99, no. 1, pp. 1–14, 2011.
12. B. Meersman, B. Renders, L. Degroote, V. Tine, and L. Vandevelde, "Control design of grid-connected three-phase inverters for voltage unbalance correction," *44th Universities Power Engineering Conference (UPEC)*, pp. 1–5, 2009.
13. A. Vinayagam, K. S. V. Swarna, S. Y. Khoo, A. T. Oo, and A. Stojcevski, "PV Based Microgrid with Grid-Support Grid-Forming Inverter Control-(Simulation and Analysis)," *Smart Grid and Renewable Energy*, vol. 8, no. 1, pp. 1–30, 2017.
14. U. B. Tayab, M. A. Bin Roslan, L. J. Hwai, and M. Kashif, "A review of droop control techniques for microgrid," *Renewable and Sustainable Energy Reviews*, vol. 76, no. May 2016, pp. 717–727, 2017.
15. W. Yao, M. Chen, J. Matas, J. M. Guerrero, and Z. M. Qian, "Design and analysis of the droop control method for parallel inverters considering the impact of the complex impedance on the power sharing," *IEEE Transactions on Industrial Electronics*, vol. 58, no. 2, pp. 576–588, 2011.
16. J. Simpson-Porco, Q. Shafiee, F. Dörfler, J. C. Vasquez, J. M. Guerrero, and F. Bullo, "Secondary Frequency and Voltage Control of Islanded Microgrids via Distributed Averaging Secondary Frequency and Voltage Control of Islanded Microgrids via Distributed Averaging," *IEEE Transactions on Industry Electronics*, vol. 62, no. April 2016, pp. 7025–7038, 2015.
17. Z. You, J. Liu, X. Zhang, T. Wu, and X. Wang, "A novel active power control strategy based on droop control method for parallel inverters," *2014 IEEE Applied Power Electronics Conference and Exposition - APEC 2014*, pp. 3072–3075, 2014.
18. J. Lee, E. Kim, and S. Moon, "Determining P-Q Droop Coefficients of Renewable Generators for Voltage Regulation in an Islanded Microgrid," *3rd*

- International Conference on Energy and Environment Research*, vol. 107, no. 9, pp. 122–129, 2017.
19. S. Ahn, J. Choi, S. Ahn, and J. Choi, “Power Sharing and Frequency Control of an Autonomous Microgrid Considering the Dynamic Characteristics of Distributed Generations Power Sharing and Frequency Control of an Autonomous Microgrid Considering the Dynamic Characteristics of Distributed Generat,” *Journal of International Council on Electrical Engineering*, vol. 2, no. 1, pp. 39–44, 2014.
 20. I. Wasiak *et al.*, “A Power-Quality Management Algorithm for Low-Voltage Grids With Distributed Resources,” *IEEE Transactions on Power Delivery*, vol. 23, no. 2, pp. 1055–1062, 2008.
 21. E. Serban and H. Serban, “A Control Strategy for A Distributed Power Generation Microgrid Application with Voltage and Current Controlled Source Converter,” *IEEE Transactions on Power Electronics*, vol. 25, no. 12, pp. 2981–2992, 2010.
 22. S. Khalid and B. Dwivedi, “Power Quality Issues, Problems, Standards and Their Effects in Industry with Corrective Means,” *International Journal of Advances in Engineering and Technology (IJAET)*, vol. 1, no. 2, pp. 1–11, 2011.
 23. O. V. G. Swathika and S. Hemamalini, “Review on Microgrid and its Protection Strategies,” *International Journal of Renewable Energy Research*, vol. 6, no. 4, pp. 1–14, 2016.
 24. J. Grandidier *et al.*, “Full Spectrum hybrid photovoltaics and thermal engine utilizing high concentration solar energy,” *IEEE 44th Photovoltaic Specialist Conference (PVSC)*, pp. 1–3, 2016.
 25. R. Nunez *et al.*, “Spectral Impact on Multijunction Solar Cells Obtained by Means of Component Cells of a Different Technology,” *IEEE Journal of Photovoltaics*, vol. 8, no. 2, pp. 646–653, 2018.
 26. V. Yaramasu, B. Wu, P. C. Sen, S. Kouro, and M. Narimani, “High-Power Wind Energy Conversion Systems: State-of-the-Art and Emerging Technologies,” *Proceedings of the IEEE*, vol. 103, no. 5, pp. 740–788, 2015.
 27. Y. Yin, M. Liao, and P. Lyu, “The Dynamic Stability Analysis of Wind Turbines under Different Control Strategies,” *5th International Conference on Electric Utility Deregulation and Restructing and Power Technologies*, pp. 1–5, 2015.

28. B. Girling and T. Lane, *World Energy Resources: Hydropower 2016*, 1st ed. World Energy Council, 2016.
29. U. Iec, F. Alvarez-cuevas-figuerola, and A. Sudri, "Centralized and Distributed Active and Reactive Power Control of a Utility Connected Microgrid," *IEEE Systems Journal*, vol. 6, no. 1, pp. 58–67, 2012.
30. A. G. Tsikalakis and N. D. Hatziargyriou, "Centralized Control for Optimizing Microgrids Operation," *IEEE Transfer Energy Converters*, vol. 23, no. 1, pp. 1–8, 2011.
31. D. E. Olivares, C. A. Cañizares, and M. Kazerani, "A Centralized Optimal Energy Management System for Microgrids," *IEEE Power and Energy Society General Meeting*, pp. 1–6, 2011.
32. X. Meng, Z. Liu, J. Liu, T. Wu, S. Wang, and B. Liu, "A seamless transfer strategy based on special master and slave DGs," *IEEE 3rd International Future Energy Electronics Conference and ECCE Asia (IFEEC - ECCE Asia)*, vol. 1, pp. 1553–1558, 2017.
33. H. Cai, J. Xiang, M. Z. Q. Chen, and W. Wei, "A Decentralized Control Strategy for Photovoltaic Sources to Unify MPPT and DC-bus Voltage Regulation," *American Control Conference*, vol. 5090, no. 19, pp. 1–6, 2017.
34. J. G. De Matos, F. S. F. Silva, and L. A. D. S. Ribeiro, "Power Control in AC Isolated Microgrids With Renewable Energy Sources and Energy Storage Systems," *IEEE Transactions on Industry Electronics*, vol. 62, no. 6, pp. 3490–3498, 2015.
35. D. Wu, F. Tang, T. Dragicevic, J. C. Vasquez, and J. M. Guerrero, "Autonomous Active Power Control for Islanded AC Microgrids With Photovoltaic Generation and Energy Storage System," *IEEE Transactions on Energy Conversion*, vol. 29, no. 4, pp. 882–892, 2014.
36. W. Yuan, J. Yang, Y. Sun, H. Han, X. Hou, and M. Su, "A novel operation mode for PV-storage independent microgrids with MPPT based droop control," *IEEE 3rd International Future Energy Electronics Conference and ECCE Asia (IFEEC)*, vol. 1, no. 17, pp. 936–941, 2017.
37. M. Shuvra and B. Chowdhury, "Autonomous Control of Smart Inverters in Grid Connected and Islanded Mode," *IEEE Power & Energy Society Innovative Smart Grid Technologies Conference (ISGT)*, pp. 1–5, 2017.
38. J. He and Y. W. Li, "An enhanced microgrid load demand sharing strategy,"

- IEEE Transactions on Power Electronics*, vol. 27, no. 9, pp. 3984–3995, 2012.
39. J. M. Guerrero, J. Matas, L. G. de Vicuna, M. Castilla, and J. Miret, “Decentralized control for parallel operation of distributed generation inverters using resistive output impedance,” *IEEE Transactions on Industrial Electronics*, vol. 54, no. 2, pp. 994–1004, 2007.
 40. P. Ye *et al.*, “An Improved Droop Control Strategy for Parallel Inverters in Microgrid,” *2017 IEEE Conference on Energy Internet and Energy System Integration (EI2)*, pp. 1–5, 2017.
 41. J. M. Guerrero, L. Hang, and J. Uceda, “Control of Distributed Uninterruptible Power Supply Systems,” *IEEE Transactions on Industrial Electronics*, vol. 55, no. 8, pp. 2845–2859, 2008.
 42. J. P. F. Bianchi, “Optimal Droop Control for Voltage Source Converters in Islanded Microgrids,” *International Federation of Automatic Control Proceedings Volumes*, vol. 45, no. 21, pp. 566–571, 2016.
 43. L. S. Araujo, D. I. Narvaez, T. G. Siqueira, and M. G. Villalva, “Modified droop control for low voltage single phase isolated microgrids,” *IEEE International Conference on Automatica, ICA-ACCA 2016*, vol. 14, no. 7, pp. 1–6, 2016.
 44. W. Cao, H. Su, J. Cao, J. Sun, and D. Yang, “Improved Droop Control Method in Microgrid and Its Small Signal Stability Analysis,” *3rd International Conference on Renewable Energy Research and Applications*, pp. 197–202, 2014.
 45. R. Jackson, S. A. Zulkifli, and N. M. Badrul Sham, “Power Flows Control Scheme for Hybrid Single Phase Energy System Using Droop Control : A Survey,” *International Review of Electrical Engineering*, vol. 13, no. 4, pp. 305–315, 2018.
 46. Z. Liu and J. Liu, “Indirect Current Control Based Seamless Transfer of Three-phase Inverter in Distributed Generation,” *IEEE Transactions on Power Electronics*, vol. 29, no. 7, pp. 3368–3383, 2014.
 47. J. Kwon, S. Yoon, and S. Choi, “Indirect Current Control for Seamless Transfer of Three-phase Utility Interactive Inverters,” *IEEE Transactions on Power Electronics*, vol. 27, no. 2, pp. 773–781, 2012.
 48. L. Meng *et al.*, “Review on Control of DC Microgrids and Multiple Microgrid Clusters,” *IEEE Journal of Emerging and Selected Topics in Power Electronics*, vol. 5, no. 3, pp. 928–948, 2017.

49. M. N. Arafat, A. Elrayyah, and Y. Sozer, "Hybrid Droop and Current Control for Seamless Transition Mode of Microgrids," *IEEE Energytech*, pp. 1–6, 2013.
50. T. S. Hwang and S. Y. Park, "A Seamless Control Strategy of a Distributed Generation Inverter for the Critical Load Safety Under Strict Grid Disturbances," *IEEE Transactions on Power Electronics*, vol. 28, no. 10, pp. 4780–4790, 2013.
51. Z. Lu, W. Li, Z. Li, H. Iu, N. Dong, and X. Liu, "Adaptive Droop Control with Self-adjusted Virtual Impedance for Three-phase Inverter Under Unbalanced Conditions," *IEEE International Symposium on Circuits and Systems (ISCAS)*, pp. 6–9, 2017.
52. B. K. Bose, "Neural Network Applications in Power Electronics and Motor Drives—An Introduction and Perspective," *IEEE Transactions on Industrial Electronics*, vol. 54, no. 1, pp. 14–33, 2007.
53. Y. Abdel-Rady Ibrahim Mohamed and E. F. El-Saadany, "An Improved Deadbeat Current Control Scheme With a Novel Adaptive Self-Tuning Load Model for a Three-Phase PWM Voltage-Source Inverter," *IEEE Transactions on Industrial Electronics*, vol. 54, no. 2, pp. 747–759, 2007.
54. R. Cardenas and R. Pena, "Sensorless Vector Control of Induction Machines for Variable-Speed Wind Energy Applications," *IEEE Transactions on Energy Conversion*, vol. 19, no. 1, pp. 196–205, 2004.
55. C. He, J. Zhao, and S. Zhang, "Adaptive Current Control Strategy Based on LCL-Filter Inverter in Weak Grid," *IEEE Innovative Smart Grid Technologies*, vol. 978, no. 16, pp. 1–6, 2016.
56. S. Mukherjee, V. R. Chowdhury, and P. Shamsi, "Model Reference Adaptive Control Based Estimation of Equivalent Resistance and Reactance in Grid-Connected Inverters," *IEEE Transactions on Energy Conversion*, vol. 32, no. 4, pp. 1407–1417, 2017.
57. M. Rashed, P. F. A. MacConnell, A. F. Stronach, and P. Acarnley, "Sensorless Indirect-Rotor-Field-Orientation Speed Control of a Permanent-Magnet Synchronous Motor With Stator-Resistance Estimation," *IEEE Transactions on Industrial Electronics*, vol. 54, no. 3, pp. 1664–1675, 2007.
58. Y. A. R. I. Mohamed and E. F. El-Saadany, "Adaptive Discrete-Time Grid-Voltage Sensorless Interfacing Scheme for Grid-Connected DG-Inverters Based on Neural-Network Identification and Deadbeat Current Regulation,"

- IEEE Transactions on Power Electronics*, vol. 23, no. 1, pp. 308–321, 2008.
59. A. Vidal *et al.*, “A Method for Identification of the Equivalent Inductance and Resistance in the Plant Model of Current-Controlled Grid-Tied Converters,” *IEEE Transactions on Power Electronics*, vol. 30, no. 12, pp. 7245–7261, 2015.
 60. X. Chen, Y. Wang, Y. Zhang, J. Chen, and C. Gong, “Hybrid damping adaptive control scheme for grid-connected inverters in a weak grid,” *IET Power Electronics*, vol. 9, no. 15, pp. 2760–2768, 2016.
 61. D. Yang, X. Ruan, and H. Wu, “Impedance Shaping of the Grid-Connected Inverter with LCL Filter to Improve Its Adaptability to the Weak Grid Condition,” *IEEE Transactions on Power Electronics*, vol. 29, no. 11, pp. 5795–5805, 2014.
 62. N. Mukherjee and D. De, “Analysis and improvement of performance in LCL filter-based PWM rectifier/inverter application using hybrid damping approach,” *IET Power Electronics*, vol. 6, no. 2, pp. 309–325, 2013.
 63. Y. Liu, Q. Zhang, C. Wang, and N. Wang, “A control strategy for microgrid inverters based on adaptive three-order sliding mode and optimized droop controls,” *Electric Power Systems Research*, vol. 117, pp. 192–201, 2014.
 64. P. H. Divshali, A. Alimardani, S. H. Hosseini, and M. Abedi, “Decentralized Cooperative Control Strategy of Microsources for Stabilizing Autonomous VSC-Based Microgrids,” *IEEE Transactions on Power Systems*, vol. 27, no. 4, pp. 1949–1959, 2012.
 65. D. De and V. Ramanarayanan, “Decentralized Parallel Operation of Inverters Sharing Unbalanced and Nonlinear Loads,” *IEEE Transactions on Power Electronics*, vol. 25, no. 12, pp. 3015–3025, 2010.
 66. Y. Chen, X. Pei, and Y. Kang, “High Power Combined Three-Phase Inverter System: Analysis, Design and Experiments,” *IEEE 6th International Power Electronics and Motion Control Conference*, pp. 1498–1503, 2009.
 67. J. Zhang and J. Ning, “Adaptive Droop Control for Accurate Power Sharing in Islanded Microgrid Using Virtual Impedance,” *IECON 2017 - 43rd Annual Conference of the IEEE Industrial Electronics Society*, pp. 1–6, 2017.
 68. M. Cespedes and J. Sun, “Adaptive Control of Grid-Connected Inverters Based on Online Grid Impedance Measurements,” *IEEE Transactions on Sustainable Energy*, vol. 5, no. 2, pp. 516–523, 2014.
 69. Q. C. Zhong, Y. Wang, and B. Ren, “UDE-Based Robust Droop Control of

- Inverters in Parallel Operation,” *IEEE Transactions on Industrial Electronics*, vol. 64, no. 9, pp. 7552–7562, 2017.
70. Q. C. Zhong, “Robust droop controller for accurate proportional load sharing among inverters operated in parallel,” *IEEE Transactions on Industrial Electronics*, vol. 60, no. 4, pp. 1281–1290, 2013.
 71. Y. Wang, Q. C. Zhong, and B. Ren, “Robust control for parallel operated L-Inverters with uncertainty and disturbance estimator,” *IEEE Energy Conversion Congress and Exposition (ECCE)*, pp. 1–6, 2016.
 72. Y. Wang, Y. Wang, B. Ren, and Q. Zhong, “Robust power flow control of grid-tied inverters based on the uncertainty and disturbance estimator Robust Power Flow Control of Grid-tied Inverters Based on the Uncertainty and Disturbance Estimator,” *American Control Conference (ACC)*, pp. 7450–7455, 2016.
 73. Y. W. Li and C. Kao, “An Accurate Power Control Strategy for Power-Electronics-Interfaced Distributed Generation Units Operating in a Low-Voltage Multibus Microgrid,” *IEEE Transactions on Power Electronics*, vol. 24, no. 12, pp. 2977–2988, 2009.
 74. G. Liu, X. Cao, T. Shi, and W. Wang, “Research on Adaptive Control of Grid-Connected PV Inverters in Weak Grid,” pp. 4229–4235, 2015.
 75. V. Inverters, “A Robust Control Scheme for Grid-Connected,” *IEEE Transactions on Industry Electronics*, vol. 58, no. 1, pp. 202–212, 2011.
 76. N. B. Lai and K. H. Kim, “Robust Control Scheme for Three-phase Grid-connected Inverters with LCL-filter under Unbalanced and Distorted Grid Conditions,” *IEEE Transactions on Energy Conversion*, vol. 33, no. 2, pp. 506–515, 2017.
 77. Y. Xu, “Robust Finite-Time Control for Autonomous Operation of an Inverter-Based Microgrid,” *IEEE Transactions on Industrial Informatics*, vol. 13, no. 5, pp. 2717–2725, 2017.
 78. S. Zuo, A. Davoudi, Y. Song, and F. L. Lewis, “Distributed Finite-Time Voltage and Frequency Restoration in Islanded AC Microgrids,” *IEEE Transactions on Industrial Electronics*, vol. 63, no. 10, pp. 5988–5997, 2016.
 79. F. Guo, C. Wen, J. Mao, and Y. D. Song, “Distributed Secondary Voltage and Frequency Restoration Control of Droop-Controlled Inverter-Based Microgrids,” *IEEE Transactions on Industrial Electronics*, vol. 62, no. 7, pp. 4355–4364, 2015.

80. S. M. Azizi, S. A. Khajehoddin, and S. Member, "Robust Inverter Control Design in Islanded Microgrids Using μ -Synthesis," *IEEE Energy Conversion Congress and Exposition (ECCE)*, pp. 3–7, 2016.
81. Y. Atia, M. M. Salem, A. Eliwa, and M. Zahran, "Simulation and Implementation of Power Control Strategy Grid Connected Photovoltaic System," *WSEAS Transactions on Systems and Control*, vol. 10, pp. 632–641, 2015.
82. F. Blaabjerg, R. Teodorescu, M. Liserre, and A. V Timbus, "Overview of control and grid synchronization for distributed power generation systems," *IEEE Transactions on Industrial Electronics*, vol. 53, no. 5, pp. 1398–1409, 2006.
83. B. Mokhtar, "Active and reactive power neurocontroller for grid-connected photovoltaic generation system," *Journal of Electrical Systems*, vol. 12, no. 1, pp. 146–157, 2016.
84. J. Hossain, N. Sakib, E. Hossain, and R. Bayindir, "Modelling and simulation of solar plant and storage system: A step to microgrid technology," *International Journal of Renewable Energy Research*, vol. 7, no. 2, pp. 723–737, 2017.
85. M. A. Abusara, S. M. Sharkh, and J. M. Guerrero, "Improved droop control strategy for grid-connected inverters," *Sustainable Energy, Grids and Networks*, vol. 1, pp. 10–19, 2015.
86. S. Dasgupta, S. K. Sahoo, and S. K. Panda, "A novel current control scheme using Lyapunov function to control the active and reactive power flow in a single phase hybrid PV inverter system connected to the grid," *The International Power Electronics Conference (ECCE - ASIA)*, pp. 1701–1708, 2010.
87. A. Micallef, M. Apap, C. Spiteri-Staines, J. M. Guerrero, and J. C. Vasquez, "Reactive power sharing and voltage harmonic distortion compensation of droop controlled single phase islanded microgrids," *IEEE Transactions on Smart Grid*, vol. 5, no. 3, pp. 1149–1158, 2014.
88. Q. Shafiee and J. M. Guerrero, "Distributed Secondary Control for Islanded MicroGrids - A Networked Control Systems Approach," *IECON 2012 - 38th Annual Conference on IEEE Industrial Electronics Society*, pp. 5637–5642, 2012.

89. J. L. Afonso, M. J. S. Freitas, and J. S. Martins, "P-q Theory power components calculations," *IEEE International Symposium on Industrial Electronics*, vol. I, pp. 385–390, 2003.
90. B. Crowhurst, E. F. El-Saadany, L. El Chaar, and L. A. Lamont, "Single-phase grid-tie inverter control using DQ transform for active and reactive load power compensation," *PECon2010 - 2010 IEEE International Conference on Power and Energy*, pp. 489–494, 2010.
91. IEEE Standards Coordinating Committee 21, *IEEE Standard 1547 for Interconnecting Distributed Resources with Electric Power Systems*, 2nd ed., no. April. New York: Institute of Electrical and Electronic Engineers, 2009.
92. M. Azri and N. A. Rahim, "Design analysis of low-pass passive filter in single-phase grid-connected transformerless inverter," *2011 IEEE 1st Conference on Clean Energy and Technology, CET 2011*, no. August 2014, pp. 348–353, 2011.
93. T. M. Blooming, N. Carolina, and D. J. Carnovale, "Application of IEEE Standard 519," *Conference Record of 2006 Annual Pulp and Paper Industry Technical Conference*, pp. 1–9, 2010.

